NUMBER GS-20-0710	General Application Specification	Amphenol ICC	
TITLE		PAGE	REVISION
BarKlip BK300 connector		1 of 4	А
		AUTHORIZED BY	DATE
		Sam Wu	Dec 06, 2021

## 1.0 OBJECTIVE

This specification provides information and requirements regarding customer application of BarKlip BK300 connector. This specification is intended to provide general guidance for application process development. It is recognized that no single application process will work under all customer scenarios and that customers will develop their own application processes to meet their needs. However, if these application processes differ greatly from the one recommended, AICC cannot guarantee results.

### 2.0 SCOPE

This specification provides information and requirements regarding customer application of BarKlip BK300 connector. These connectors provide a means of bringing high current from Bus bar conductors to Bus bar.

### 3.0 GENERAL

This document is meant to be an application guide. If there is a conflict between the product drawings and specifications, the drawings take precedence.



Figure 1 BK300 Connector (10161933)

### 4.0 DRAWINGS AND APPLICABLE DOCUMENTS

- AFCI PRODUCT SPECIFICATION: GS-12-1693
- AFCI PRODUCT DRAWINGS: 10161933

Product drawings and AFCI's GS-12-1693 Product Specification are available at <u>www.amphenol-icc.com</u>. In the event of a conflict between this application specification and the drawing, the drawing will take precedence. Customers are advised to refer to the latest revision level of AFCI product drawings for appropriate details.

### 5.0 APPLICATION REQUIREMENTS

#### 5.1 General application

Blind mate: Connector can handle adverse tolerances and allow reliable mating to misaligned Bus bar. Bus bar misalignment: ± 2.0 mm.

Mates directly to a single pole power Bus Bar

Ideal for high current Bus Bar power supply/distribution applications

NUMBER GS-20-0710	General Application Specification	Amphenol ICC	
TITLE		PAGE	REVISION
BarKlip BK300 connector		2 of 4	А
		AUTHORIZED BY	DATE
		Sam Wu	Dec 06, 2021

#### 5.2 Connector assembled part

The assembled picture of BK300 mated with mating Bus-bar and mounting Bus-bar is shown in following:



The assembled components are shown in following:



S. NO	DESCRIPTION	QTY	REMARK
1	BK300 connector	1	Supplied by
2	Washer	2	
3	#8-32 screw	2	Amphenoi
4	Mating Bus-bar	1	Supplied by
5	Mounting Bus-bar	1	the customer

### 5.3 Mating Bus bar

The Bus bar Power Conductors shall comply with the following requirements: Recommended material: C11000, solid blade Material Thickness:  $3.0\pm0.1$  mm

Surface roughness in contact area: Ra 1.6 µm maximum

Plating in contact area: 3  $\mu m$  min Silver over 1.27  $\mu m$  min Nickel

Mating edges: 0.5 mm minimum, rounded after 1\*2 chamfered



NUMBER GS-20-0710	General Application Specification	Amphenol ICC	
TITLE		PAGE	REVISION
BarKlip BK300 connector		3 of 4	A
		AUTHORIZED BY	DATE
		Sam Wu	Dec 06, 2021

## 5.4 Mounting Bus bar

Recommended mounting Bus bar is shown in following:



With 3.0mm Thickness

## 5.5 Connector fixing part

a. Screw

Recommended screw is shown in following:

#8-32 screw, torque: 2.2 N·m

## b. Washer

Recommended washer is shown in following:

Washer , internal diameter: 4.77mm, outside diameter: 9.50mm, thickness: 1mm

NUMBER GS-20-0710	General Application Specification	Amphenol ICC	
TITLE	E PAGE RE		REVISION
BarKlip BK300 connector		4 of 4	A
		AUTHORIZED BY	DATE
-		Sam Wu	Dec 06, 2021

# 6.0 RECORD RETENTION

<u>REV</u>	PAGE	DESCRIPTION	EC#	DATE
А	All	Initial release	N/A	12/06/2021